

Schedule of Requirement.

WEB TENDER NO. 10010426-083-DKN-2023

**HIRING OF 725 kVA DIESEL GENERATOR SET FOR DAKHNI CAMP
DURING ATA-2023**

| Sr. No | Item Description and Specifications | Quantity | Quoted rent for 20 days |
|--------|--|---|-------------------------|
| 1. | HIRING OF 725 kVA DIESEL GENERATOR SET FOR DAKHNI CAMP DURING ATA-2023 | 01 | PKR |
| 2. | Mob/Demob charges (as per clause 8) | | PKR |
| | | Total (inclusive of all taxes and duties) | |

ANNEXURE "A"

TERMS AND CONDITIONS

Sealed bids are invited under Competitive Bidding Procedure on Single Stage single Envelope Bidding Procedure. The bid shall contain both financial proposal and technical proposal.

01. Bidders are required to download the master set of tender documents from www.ogdcl.com under the title "Tender". Bidder shall follow the instruction mentioned in the master tender documents.
02. 100% payment will be made only payable to supplier's company after completion of assignment and submission of invoices, GST invoices and FBR Annex "C" where applicable with required documents and completion of store and accounts procedures.
03. The payment shall be made as per actual against verified invoice from I/C Electrical & Plant Manager.
04. All admissible taxes will be deducted as per rules.
- 05. Power cable for full load capacity for three phase with neutral with lugs shall be provided by the supplier / contractor with the generator. The length of each cable must not be less than 10 meters.**
- 06. The supplied Generator shall be equipped with control panel having necessary protections and circuit breaker according to load requirement.**
- 07. Generator voltage level shall be 400VAC Three Phase and 220/230VAC on single phase at 50 HZ frequency.**
08. Bidder should quote mob/demob of geneset, however OGDCL may consider mob/demob in our own scope and it will be accordingly not paid to supplier. Accordingly, Unloading & loading of Diesel generator will be provided by OGDCL at OGDCL site under supplier's supervision. OGDCL will not be responsible for any damage occurred during unloading / loading of Diesel generator.
09. Operation/servicing staff will be provided by the supplier.
10. OGDCL will provide accommodation for only 03 Nos. of operation/servicing staff.
11. OGDCL will provide supply of HSD and water only at site for Diesel generator.
12. OGDCL will not be responsible for any damage/loss to generator at site during operation.
13. Installation & Commissioning of supplied generator will be done by the supplier.
14. Servicing of the generator, routine maintenance, Top End, Mini & Major Overhauling trouble shooting will be done by the supplier.
15. Lubrication and supply of necessary consumables like lube Oil, lube Oil Filters, Air Filters & Diesel generator parts shall be supplied by the supplier.

16. Stationary to maintain the Gen Set record shall be supplied by the supplier and complete logging shall be provided after completion of assignment.
17. Last maintenance record, Total Running Hours and Year of manufacturing of supplied generator shall be provided by the supplier in technical evaluation.
18. The supplied generators shall be capable (as a prime source) to cater continuous residential camp loads 24 hours for electricity and air conditioners use as per generator rating.
19. The contract time will start when generator to be put on load by the site team.
20. Contractor to deliver the genset at site within 7 days of issuance of LOI.
21. In case of complete failure of generator set, the supplier has to provide replacement within 12 hrs of Diesel generator having same capacity.
22. In case of malfunction / stoppage of Diesel generator at site, the deduction will be made in the following manner:

| | | |
|---|--|---|
| a | Continuous stoppage for more than 06 hrs. | Deduction of full day payment. |
| b | Continuous stoppage for more than 12 hrs. | To replace the generator set with deduction of 02 full day payment. |
| c | Failure to replace/repair the gen set within 24 hrs. | The contract will be cancelled without any claim. |

23. Bidders are required to quote in Annex "C" format. Price quoted shall include all applicable taxes.
24. The supplier will have minimum of 05 years of past experience in the supply of same item.
25. Supply from Diesel generator will be required to start from tentative date i.e. July 22 to August 10, 2023 for 20 days. However, OGDCL will inform regarding mobilization of Diesel generator one week before ATA.
26. Generator shall be ready to start before ATA-2023 tentative date.
27. The tender committee reserves the right to increase or decrease the number of days on same rates or may cancel the tender without assigning any reason thereof. The payment will be made according to days, the generator utilized.

TECHNICAL PROPOSAL

Bidder's Data

Bidders are required to complete the following Form and Provide with Quoted item for technical Evaluation.

| | |
|--|--|
| Company Name: | |
| Company-Address: | |
| Contact Person, Name, Designation, ID Card No. | |
| Contact No. Phone/Mobile/ Fax/CNIC. | |
| Email Address: | |
| NTN and GST Reg No. (Please provide Copies of Reg) | |
| Please mention product name/ code/ Manufacturer data | |

Signature of Bidder: _____

Name: _____

NIC No. _____

Address: _____

(Please attach copy of NIC of bidder and contact Person)

ANNEXURE "C"

FINANCIAL PROPOSAL

| Sr. # | Description | Qty Required | Rent for 20 days | Total (inclusive of all taxes and duties) |
|--|--|--------------|------------------|---|
| 01 | HIRING OF 725 kVA DIESEL GENERATOR SET FOR DAKHNI CAMP DURING ATA-2023 | 1 | | |
| 2 | Mob/Demob charges (as per clause 8) | | | |
| Total Amount (Inclusive of All Taxes) | | | | |

Name: _____

Signature: _____

Company Seal: _____

Date: _____

Contact No. _____

