

## Schedule of Requirement

## ANNEXURE-A


### Description and Quantity Requirements:

<b>Sr. #</b>	<b>Description</b>	<b>Unit Rate (Rs.)</b>	<b>Qty. Required</b>	<b>Total Rate (Inclusive all Taxes) (Rs.)</b>	<b>Remarks</b>
<b>01</b>	<b>Lighting Poles</b> Hot Dip Galvanized (Specifications as per drawing attached)		<b>24 Nos</b>		


### Terms and Conditions for Tender

1. Bids to be submitted on Single Envelope basis.
2. Evaluation criteria of the bids shall be "full consignment wise". (Technical & Financial evaluation shall be carried out on the complete scope of supply).
3. The parts to be delivered at Nashpa Oil Field. The delivery charges are in the scope of supplier/ bidder.
4. Any required technical clarification/details regarding the material to be supplied must be cleared before submission of bid. No change in submitted bid will be entertained after bid submission date.
5. The consignment will be accepted after final inspection at site, and payment will be made through Cross Cheque after inspection of material.
6. The firm should have valid NTN and GST number and have active status on FBR website.
7. The Firm should have active Professional tax certificate of concerned Excise office where operating business.
8. Tax submission Certificate (Annex-C) will be provided along with Invoice.
9. The spares to be supplied must be in original OEM packaging with standard warranty.

# LIGHTING POLE



*NOTE:- 4 Holes of 1" for insertion of 3/4" studs.*



**DETAIL "A"  
BASE PLATE**

### POLE SPECIFICATIONS

PIPE MATERIAL	THICKNESS
Carbon Steel ASTM A-106	5-6 mm.

### BASE PLATE DIMENSIONS

X x Y x T (mm)	C (mm)
460 x 460 x 16	360