

OIL & GAS DEVELOPMENT COMPANY LIMITED
PROCUREMENT DEPARTMENT, ISLAMABAD
FOREIGN SECTION E

(To be completed, filled in, signed and stamped by the principal)

ANNEXURE 'A'

Material INSTRUMENTS FOR SLUG CATCHER OF DAKHNI PLANT
Tender Enquiry No PROC-FE/CB/P&P/DKN-4062/2018
Due Date
Evaluation Criteria FULL

SCHEDULE OF REQUIREMENT

Sr No	Description	Unit	Quantity	Unit Price (FOB)	Total Price (FOB)	Unit Price C & F BY SEA	Total Price C & F BY SEA	Deviated From Tender Spec. If Any
1	Displacer Type Level Transmitter	Detail specifications mentioned	Number	1				
2	Displacer Type Level Transmitter	Detail specifications mentioned	Number	1				
3	Level control valve	Detail specifications mentioned	Number	1				
4	Pressure safety valve	Detail specifications mentioned	Number	1				

Note:

NOTE:

1. **Bid bond**; - Pursuant to tender clause # 2.2, 11.4, 13 & 35.3.2, bid bond amounting USD 1,000/- (United States Dollar One Thousand only) or equivalent in Pak Rupees should be submitted with the technical bid.
2. **Foreign Procurement Payment Terms (also available at OGDCL website (Tenders Tab) Tender value less than or equal to US\$ 200,000:**
 Payment to the Contractor/ bidder in foreign currency shall be made by establishing in favor of the Contractor an irrevocable Letter of Credit (hereinafter called the L/C). 70 % Payment (s) under the L/C will be made for the FOB/ CFR / CPT (as the case may be) price of material of each shipment upon submission of the shipping documents. Balance 30% Payment will be released after receipt, inspection and acceptance of material.
Tender value more than US\$ 200,000:
 Payment to the Contractor/ bidder in foreign currency shall be made by establishing in favor of the Contractor an irrevocable Letter of Credit (hereinafter called the L/C). 80 % Payment (s) under the L/C will be made for the FOB/ CFR / CPT (as the case may be) price of material of each shipment upon submission of the shipping documents. Balance 20% Payment will be released after receipt, inspection (in addition of pre-shipment inspection) and acceptance of material.
3. **Evaluation Criteria**: - FULL CONSIGNMENT WISE ON CFR BY SEA KARACHI BASIS.
4. **Shipment from ACU member Countries**:- In case of shipment from ACU member countries, the LC beneficiary should be of that particular country from where the consignment is being shipped.
5. **Terms and conditions**:-Bidders are advised to carefully read all the terms and conditions of the Tender Document available at OGDCL website in the master tender document and attached technical Terms & Conditions.
6. **Delivery Period**: 45 days after establishment of LC.

Handwritten: 2/letter 5/BJ 19.2018

Details of Tender Enquiry No. PROC-FE/CB/P&P/DKN-4062/2018

Item # 1

Displacer Type Level Transmitter

Displacer Length: 48" (1219 mm) Interface;Calibration: 0.8 / 1.00;Displacer Material: Stainless steel;Nace construction MR-01-75;Process connection: 2" ANSI 600 LBS RF;Connection Style: Side/ Side;Power supply :24 VDC;Output: 4-20 mA + Hart;Electronics: SIL 2/3 certified;Display: Digital;Keypad: Yes;Mounting: Integral;Ingress protection: IP66;Approval: ATEX II 1/2 G EX d IIC T6;Cable Entry: 3/4" NPT-F ; Housing Material: Cast aluminium

Item # 2

Displacer Type Level Transmitter

Displacer Length: 48" (1219 mm) Water;Calibration: 1.00;Displacer Material: Stainless steel;Nace construction MR-01-75;Process connection: 2" ANSI 600 LBS RF;Connection Style: Side/ Side;Power supply :24 VDC;Output: 4-20 mA + Hart;Electronics: SIL 2/3 certified;Display: Digital;Keypad: Yes;Mounting: Integral;Ingress protection: IP66;Approval: ATEX II 1/2 G EX d IIC T6;Cable Entry: 3/4" NPT-F ;Housing Material: Cast aluminium

Item # 3

Level control Valve

Type: Globe ; size: 2" RF 600LB for condensate service (12%H2S) Failure class: Fail to close,
Operated: Pneumatic operated (3 - 15 PSI) Control signal: 4-20 mA with complete accessories (Positioner and I/P convertor), suitable for hazardous area, NACE compliance: Yes, Leakage Rate (Class to ASME FCI 70-2) Class VI;Normal Pressure 1250 PSI;Max. Pressure 1325 PSI

Item # 4

Pressure Safety Valves

Ssize 2", Set pressure set point 1450 PSIG and reset Pressure 1425 PSIG, Connection size 2" RF 600LB, Wet parts should be NACE compliance. (Sour gas)

TERMS AND CONDITIONS.

1. STANDARD WARRANTY /GURANTTEE FOR ALL ITEMS.
2. MANUFACTURER SHOULD BE ISO 9001 - 2000 CERTIFIED.
3. OEM LITERATURE FOR QUOTED ITEM.
4. STANDARD TEST / QUALITY CONTROL DOCUMENT/CERTIFICATES FOR ALL THE QUOTED ITEMS.
5. REFERENCE FOR SIMILAR TYPE OF MATERIAL ALREADY SUPPLIED VERIFIABLE BY E-MAIL/PHONE/FAX.