

TECHNICAL EVALUATION REPORT

Procurement of "Motors for Heat Exchangers" for Sinjhoru Gas Field against TE # PROC-LE/PT/SGF/17010-A/17.

Sr .#	Name of Bidder	Technical Responsive (Yes / No)	Reason of Rejection
1	M/S Aziz Engineering, Karachi.	No	The bidder has quoted delivery period of 180 days which is not as per SOR of Tender documents. Moreover the bidder has disclosed the prices in the technical clarification, which is against single stage Two envelope bidding procedure.
2	M/S Enersol, Lahore (Main BID)	No	The quoted specifications (Hazardous CERT, Full load current 51.0 Amp, Frame Size, Motor Heaters (Anti Condensate) & Starting Mode) are not as per Annexure A of SOR.
3	M/S OTC, Lahore	No	The quoted specifications (Frame Size, Hazardous certification & Main cable box to suit 25MM2) are not as per Annexure A of SOR.
4	M/S FAM Impex, Lahore	No	The quoted specifications (Frame Size, Hazardous certification & Main cable box to suit 25MM2) are not as per Annexure A of SOR.
5	M/S SAMTEK Energy Tools, Islamabad	Yes	
6	M/S SALARIA & Shaikh, Islamabad	No	The quoted specifications (Hazardous CERT, Insulation class, Main cable box to suit 25MM2, Insulation Class Full F not mentioned, Frame Size, Motor Heaters (Anti Condensate), Starting Mode & Delta connection) are not as per Annexure A of SOR.
7	M/S Speedy Automation, Karachi	No	The quoted specifications (Hazardous CERT, Insulation class, main cable box to suit 25 MM2, insulation class not mentioned, Frame Size, Motor Heaters (Anti Condensate) & Starting Mode are not as per Annexure A of SOR.
8	M/S MAS Associates, Islamabad	Yes	
9	M/S Petro Allied Solutions, Islamabad	No	The quoted specifications (Frame size) are not as per Annexure A of SOR.
10	M/S Enersol, Lahore (Alternate BID)	Yes	