

Technical Evaluation Report
Tender Enquiry #: PROC-LD/CB/P&P/17121/2017
(Procurement of explosion proof LED Flood Lights)

Sr. #	Bidder Name	Technically Responsive (Yes/ No)	Reasons for Rejection/Remarks
1	M/S MIDDLE EAST AUTOMATION & CONTROLS SERVICES (MACS), LAHORE	Yes	Bidder quoted two different makes for same item nos. 1)- Ref item-01, Ref item-01,lights of two different makes are quoted both are acceptable technically but finally having lower price will be considered. 2)- Ref item-02,light of Larson make is accepted while light of Stahl make is rejected due to non-compliance of its wattage with SOR.
2	M/S HZ TRADERS, KARACHI	Yes	N.A.
3	M/S FAM IMPEX, LAHORE	Yes	N.A.
4	M/S DYNAMICS ENGINEERING SERVICES, KARACHI	Yes	N.A.