

TECHNICAL EVALUATION REPORT (TER)

TENDER ENQIRY NO. PROC-LE/PT/RO/17127/17

RO PLANT FOR DAKHNI PLANT

Date: 28-12-2017

Sr. #	Bidder's Name	Technically responsive	Reason for Rejection
1	M/s Prime Chemicals Corporation, Karachi	Yes	N/A
2	M/s Tricom Power, Karachi	No	Deviate the OGDCL TOR Clause – 4. ISO certification for Tricom and HOH is not provided.
3	M/s Shahnaz International, Islamabad	No	Deviate the OGDCL TOR Clause-17, The bidder provided under specs bid i.e. 5m3/hr = 22GPM, while required capacity is 25 GPM.
4	M/s Diyan Hassan Intl. Trading, Lahore	Yes	N/A
5	M/s Chemicals Kinetics, Lahore	Yes	N/A