

**TECHNICAL EVALUATION REPORT**  
**PROCUREMENT OF PRESSURE CONTROL VALVE FOR KPD-TAY PLANT**  
**TENDER NO. PROC-LD/PT/P&P-17139/17**

S.N	Bidder Name	Technically Responsive (Yes/No)	Reasons for Rejection
1.	M/S Technobiz (Pvt) Ltd Karachi	Yes	N/A
2.	M/S Evergreen Chemical International Company Islamabad.	No	Noise is exceeding 85 dB(A) Offered positioner is not linkage less.
3.	M/S Maxwell Automation Lahore.	No	Offered positioner is not linkage less.

*Faisal*  
28/12/17  
**FAISAL RAFIQ**  
Senior Engr. (Inst.)  
P&P-South-8  
Ext: 2788