

TECHNICAL EVALUATION REPORT

TENDER ENQUIRY NO. PROC-LD/ADMIN-17166/17, Air Circuit Breaker

Sr. No.	Bidder's Company	Technical Responsive Yes/No	Remarks
1	M/s M.K Engineering Services	Yes	----
2	M/s Enerquip Pvt Ltd	No	<ul style="list-style-type: none">• Didn't comply Sr# 1 of terms & conditions as the quoted ACB's are not compatible (in size/ dimensions etc) in the already installed Auto Transfer Switch and Synchronization panels.
3	M/s Shahnaz International	No	<ul style="list-style-type: none">• Didn't comply Sr# 1 of terms & conditions as the quoted ACB's are not compatible (in size/ dimensions etc) in the already installed Auto Transfer Switch and Synchronization panels.• Didn't comply Sr# 5 of terms & conditions(Quoted items are not as per the standards already installed in the system)