


TECHNICAL EVALUATION REPORT

**TENDER ENQUIRY # PROC-~~EE~~/PT/ADMIN-17538/2018, 300 KVA GEN SET FOR
FIRE PUMPS INSTALLED AT OGDCL HOUSE**

S#	Principal / OEM	Local Agent	Technically responsive Yes/No	Remarks
1	CATERPILLER SARK, UK	M/s AESL Islamabad	No	<ul style="list-style-type: none">Power is not guaranteed at 50 degree C and 550 meter altitude(Sr# 3.2 of Terms & conditions not complied)
2	Power link (UK)	M/s MECATECH	No	<ul style="list-style-type: none">No after sale service/Workshop facility at Islamabad/Rawalpindi (Sr# 4(IV) of Bidder's eligibility criteria not complied)Power is not guaranteed at 50 degree C and 550 meter altitude (Sr# 3.2 of Terms & conditions not complied)Bill of lading to import said gensets by the bidder (at least 05 Nos) not provided (Sr# 4(V) of Bidder's eligibility criteria not complied).
3	AGG Power Tech(UK)	M/s HNL	Yes	-----
4	ONIS VISA (Italy)	M/s VPL Ltd	Yes	-----



Ghulam Khaliq
HSEQ Officer



Najeeb Uddin Muhammad
DCE(Elect)



Habib Akbar
SE(HSEQ)