

Technical Evaluation Performa
PROC-LA/PT/P&P/17628/2019 (UCH-II Membrane elements)

S/No	Bidder/Manufacturer	Technically responsive (Y/N)	Remarks
1	M/s Evergreen Chemical International Company, Islamabad M/s Hunan Keensen Technology Co. China (Manufacturer)	No	Does not Comply with Tender Requirement. <u>Deviations</u> <ul style="list-style-type: none"> Quoted specification of feed water flow is not equivalent to recommended brand in SOR. As per tender clause 6.5, letter regarding performance comment of quoted brand in Pakistan is not available.
2	M/ Samtek Energy Tools , Islamabad M/s Koch Membrane System, Inc. USA (Manufacturer)	Yes	~
3	M/s Sara Enterprises, Islamabad M/s Koch Membrane System, Inc. USA (Manufacturer)	Yes	~
4	M/s Speedy Automation, Islamabad M/s Hunan Keensen Technology Co. China (Manufacturer)	No	Does not Comply with Tender Requirement. <u>Deviations</u> <ul style="list-style-type: none"> Quoted specification of feed water flow is not equivalent to recommended brand in SOR. As per tender clause 6.5, letter regarding performance comment of quoted brand in Pakistan is not available.
5	M/s Prime Chemical Corporation, Karachi M/s Lanxess Lewabrone, Germany (Manufacturer)	Yes	Technically responsive only for LEWBRANE RO B 400 FR ASD membrane.

Sohail Anwar
SOHAIL ANWAR
 Manager (P&P)
 Oil & Gas Development
 Islamabad

14/6/19

Hajra Khatoon
HAJRA KHATOON
 Chemist (P&P)-QA/QC
 Ext: 3344

14/6/19