


TECHNICAL EVALUATION REPORT

TENDER NO. PROC-FC/CB/PROD/UCH-II-3128/2017

Level Gauges, Level transmitters, PCV/FCV spares & DPTs

Group-A (Level Gauges & Level Transmitters)				
Sr. No.	Bidder	Local Agent	Technically Responsive (Yes/No)	Reason for Rejection
1	M/s Samtek International Inc., USA	M/s Samtek (Energy) International Pakistan, Islamabad	Yes	—
2	M/s WIKA Middle East FZE, UAE	M/s Maxwell Automation, Lahore	Yes	—
3	M/s KRJ Incorporated, Canada	M/s Dynamic Engineering, Karachi	No	1. Material Specification deviation regarding Bottom stand-off length of level gauge 2. Specification deviation regarding provision of required certification for level Gauges
4	M/s SAT International, Lahore	M/s SAT International, Lahore	Yes	—


AFTAB AHMAD SHAIKH
Dy. Chief Engineer
Oil & Gas Dev. Co. Ltd.

Group-B (PCV/FCV Spares)

Sr. No.	Principle	Local Agent	Technically Responsive (Yes/No)	Reason for Rejection
1	M/s Valvitalia SPA, Italy	M/s Petrochem Supply Co., Karachi	Yes	—

Group-C (Differential Pressure Transmitters)

1	M/s pearl Engineering Pvt. Ltd., Karachi	M/s pearl Engineering Pvt. Ltd., Karachi	Yes	—
2	M/s Samtek International Inc., USA	M/s Samtek (Energy) International Pakistan, Islamabad	Yes	—