

TECHNICAL EVALUATION REPORT
Tender Enquiry # PROC-FA/CB/RMP/PUMP-3164/2017
Procurement of Trolley Mounted Diesel Engine Driven Fire Pump.

S.#	Name Of Bidder	Local Agent	Responsive/ Non-Responsive	Reason of Declaring Non-Responsive
01	M/s.OILMAN GROUP LIMITED, CHINA.	M/s.OILMAN GROUP LIMITED, ISLAMABAD.	Non-Responsive	<ul style="list-style-type: none">i. UL certification is not being verified by searching UL online certification directory at www.ul.com/database mentioned on the submitted certificate of compliance.ii. Main Assys. of trolley mounted diesel engine driven fire pump i.e. pump, engine and controller need to be UL listed, FM approved and NFPA20 compliant as per SOR whereas the bidder mentioned UL listed only against pump and which is also not being verified by searching UL online certification directory as mentioned above.iii. Accessories portion of Pump Fittings & Accessories described at Sr.No.3 of data / compliance sheet is not complied.