

TECHNICAL EVALUATION REPORT TENDER NO. PROC-LE/PT/PROD/18115/20

AIRCONDITIONERS FOR KUNNAR/KPD

Sr. No.	Bidder Name	Technically Responsive (Yes/No)	Reason for Rejection
1	M/s Pak Elektron Limited, Lahore	Yes	—
2	M/s MEP (Pvt) Ltd, Islamabad	No	Deviation of material specification as per tender documents (Non provision of T3 compressor technology)
3	M/s JAM SUNG Pvt. Limited, Lahore	No	Deviation of material specification as per tender documents (Non provision of T3 compressor technology)