

TECHNICAL EVALUATION REPORT

TENDER NO. PROC-LC/PT/PROD/18467/21

Solar Power Maintenance Free Batteries for KPD-TAY Well Sites

Sr. No.	Bidder	Technically Responsive (Yes/No)	Reason for Rejection
1	M/s Makkays, Pakistan	No	i. Specification deviation against Sr.No.10, 11 & 12 of Annexure-Y of Tender document regarding dimensions / sizes of the batteries. ii. Specification deviation against Sr.No.16 of Annexure-Y of Tender document regarding Operating temperature of the batteries.
2	M/s Benchmark Technologies, Pakistan	No	i. Deviation against Procurement manual clause 2.10, which states "Bidder who disclose quoted price anywhere in technical document under Single stage Two envelope and Two stage Two envelope bidding procedure, their bid shall be rejected".
3	M/s Shaheen Services, Pakistan	No	i. Specification deviation against Sr.No.10 & 12 of Annexure-Y of Tender document regarding dimensions / sizes of the batteries. ii. Specification deviation against Sr.No.15 & 16 of Annexure-Y of Tender document regarding internal resistance and operating temperature of the batteries.

4	M/s Techno Star Company, Pakistan	No	i. Specification deviation against Sr. No. 5 & 6 of Annexure-Y of Tender document regarding shelf life and Manufacturing Status of the batteries.
5	M/s O.K. Agencies, Pakistan	No	i. Specification deviation against Sr.No.10, 11 & 12 of Annexure-Y of Tender document regarding dimensions / sizes of the batteries.
6	M/s Osprey Industrial Solutions, Pakistan	Yes	—
7	M/s ASR Traders & Builders, Pakistan	No	<p>i. Specification deviation against Sr. No. 8 of Annexure-Y of Tender document regarding Terminal type of the batteries.</p> <p>ii. Specification deviation against Sr. No. 10, 11 & 12 of Annexure-Y of Tender document regarding dimensions / sizes of the batteries.</p> <p>iii. Specification deviation against Sr.No. 16 of Annexure-Y of Tender document regarding Operating temperature of the batteries.</p>