

For Web Posting

TECHNICAL EVALUATION REPORT
PROC-SERVICES/CB/SYSTEM-4328/2019

Sr. No	Bidder Name	Technically Responsive (Yes/No)	Reason if Non responsive
1	M/S Premier Systems Pvt. Ltd.	Yes	
2	M/S CNS Engineering	Yes	
	M/S IOTA Solutions Ltd.	No	<p>Bidder unable to provide required professional level of technical details regarding offered solution for;</p> <ul style="list-style-type: none">• LV Switchgear and LV distribution panels / boards• Motorized Arrangement to Drain Out Flood/leakage Water with Automatic Sensor• LED Signs <p>Bidder do not quote required modular UPS mentioned in TOR which is 60 KVA (N+1) online double conversion modular UPS, Scalable up to 120 KVA. Whereas in 1st stage exactly right UPS was quoted and hence model was qualified for 2nd stage and incorporated in TOR</p>