## **TECHNICAL EVALUATION REPORT**

## RFP NO.: OGDCL-SCM-LC-WT-COMMN-BATTERY- Doc268577196-2024

## **DESCRIPTION OF THE RFP: Replacement of EPABX Backup Batteries**

**TECHNICAL BID OPENING DATE: 03-12-2-24** 

S. No.	Name of Bidder	Status (Technically Responsive/ Non- Responsive)	Remarks (Reasons of Rejection)
1	M/s Makkays Pvt. Ltd.	Technically Non- Responsive	Quoted Battery have design life of 10 years and don't have centralized H2 gas vent kit.
2	M/S Onyx	Technically Responsive	
3	M/S OWT	Technically Responsive	
4	M/S Profound	Technically Non- Responsive	Quoted Battery don't have Polymer Gel and vendor did not responded on clarification.
5	M/S Shahnaz International	Technically Responsive	
6	M/S Shiekh	Technically Non- Responsive	Quoted Battery have design life of 7 - 10 years and don't have centralized H2 gas vent kit.
7	M/S UHL	Technically Non- Responsive	Didn't meet the specs and also didn't get the qualifying marks as mentioned in Annex-I of TOR.

## Note:

- 1. Bidder may submit grievance within Seven (07) days of announcement of Technical Evaluation Report.
- 2. The grievance if any shall be sent to <a href="mailto:bgrc@ogdcl.com">bgrc@ogdcl.com</a> as per format available on OGDCL website.