Technical Evaluation Report

Tender Enquiry #: PROC-LE/PT/P&P-17781/2019

Sr. #	Bidder Name	Technically Responsive Yes/ NO	Reason for Rejection
1.	M/S KSB PUMPS COMPANY LIMITED	YES	
2.	M/S HMA PUMPS PVT LTD		Required Flow:30 GPM, with Head: 344 Ft as per Data Sheet provided Whereas Quoted Values of pump DSV 8 10 by M/S HMA Pumps Quoted Flow: 6.8 m³/hr (30 GPM) Quoted Head: 105 Meter (344 Ft) Corresponding Values from technical literature of pump DSV 8 10:- Flow: 7 m³/hr (30.82 GPM) Head: 97 Meter (318.41) Flow: 6m³/hr (26.41 GPM) Head: 100 Meter (328 Feet) Repeated emails were sent to the bidder to clarify the above mentioned difference between quoted pump and technical literature however bidder have not responded the queries. Therefore from technical literature the quoted pump is under capacity. Hence declared as technically non reponsive
3.	M/S EXCEL TECHNOLOGY PVT LTD	YES	

M Ahsan Waqar Khan
J.E (Mech.)-North B
Ext: 2684