

TECHNICAL EVALUATION REPORT TENDER NO. PROC-LD/PT/PE&FD-17829/19
FOR ELECTRICAL ITEMS

Sr. No.	Bidder Name	Technically Responsive (Yes/No)	Reason for Rejection
1	M/s Fast Cables Limited, Islamabad	Yes for Group "C"	-
2	M/s Angular Power Automation, Lahore	Yes for Group "A" & "B"	-
3	M/s Control System Engineering, Lahore	No for Group "A"	Bidder quoted Sodium Safety Flood Lights having 35,780lumens as against OGDCL requirement of 48,000lumens. This is deviation of tender specifications.
4	M/s HZ Traders, Karachi	Yes for Group "A" & "C"	-
5	M/s Enerquip (Pvt) Ltd. Islamabad	Yes for Group "A"	-
6	M/s ABC Enterprises Rawalpindi	Yes for Group "A", "B" & "C"	-
7	M/s Ayyans Enterprises Rawalpindi	Yes for Group "A"	-