

TECHINCAL EVAUALTION REPORT

For the procurement of Supply, Installation. & Commissioning of MV Switchgear for Uch Gas Field against

TE # PROC-LD/PT/P&P/UCH/18140/20

Sr. #	Name of Principal	Technical Responsive (Yes / No)	Reason of Rejection
1	M/S Prince Automation Karachi	No	The Bidder disclosed prices in Annexure-A of SOR during technical evaluation, which is against Single stage Two Envelope Bidding Procedure.
2	M/S Trading 360, Islamabad	No	The offered Protection relay in (Metering & Protection Equipment) does not provide all the Protections as per Annexure-A of SOR.
3	M/S Arson Engineering Karachi	No	The Bidder did not provide the clarifications reply regarding provision of Annexure-A of SOR.
4	M/S Osprey Industrial Solutions, Islamabad	Yes	Nil
5	M/S Tri Tech(Pvt) Ltd, Lahore	Yes	Nil
6	M/S Transfo Tech Engineering Karachi	Yes	Nil