

Technical Evaluation Report

Tender Enquiry # PROC-LD/PT/P&P/DKN-18318/2021.

(Procurement of 110 V DC Battery Charger for Dakhni Plant)

Sr. #	Bidder Name	Technically Responsive (Yes/ No)	Reasons for Rejection/Remarks
1	M/S INNOVIV PAKISTAN Pvt LIMITED, LAHORE	(No)	Bidder offered the charger panel with different dimensions as required and with no circuitry for providing charger selection which is contradictory to our SOR & TOR (Ref: S#11 & 13 of compliance confirmation sheet).
2	M/S TECHNOLINKS, LAHORE	(No)	Bidder offered the charger panel with different dimensions as required and with no circuitry for providing charger selection which is contradictory to our SOR & TOR (Ref: S#11 & 13 of compliance confirmation sheet).
3	M/S ENERSOL, LAHORE	(Yes)	N/A
4	M/S AL-RAHEEM CORPORATION, LAHORE	(Yes)	N/A
5	M/S ENERQUIP Pvt. LIMITED, ISLAMABAD	(Yes)	N/A
6	M/S MAS ASSOCIATES Pvt LIMITED, LAHORE	(Yes)	N/A