

TECHNICAL EVALUATION REPORT

RFP NO.: OGDCL-SCM-LD-PT-PNP-Chanda-249537193-2024

DESCRIPTION OF THE RFP: Procurement of Fire Water Jockey Pump for Chanda Plant

TECHNICAL BID OPENING DATE: 23-07-2024

S. No.	Name of Bidder	Technically Responsive	Remarks (Reasons of Rejection)
1.	M/s KSB Pumps Co. Ltd., Lahore	YES	n/a
2.	M/s MAS Associates Pvt. Limited, Lahore	NO	Non-compliance with specifications of the item as mentioned in Section 4.1 and TOR at Section 3.1 of Ariba RFP (pressure of the offered pump is not within acceptable range, i.e. 125 psi or 14% higher)

Name	Asad Khaliq		
Designation	Senior Engr. (Mech)		
Extension	4181		

Note:

1. Bidder may submit grievance within Seven (07) days of announcement of Technical Evaluation Report.
2. The grievance if any shall be sent to bgrc@ogdcl.com as per format available on OGDCL website.