



OIL & GAS DEVELOPMENT COMPANY LIMITED
KPD-TAY / KUNNAR GAS, LPG PLANT & OIL FIELD
Phone # 022-2761404 & Fax # 022-2761405

SCHEDULE OF REQUIREMENT

TENDER ENQUIRY # TE/01-A/KPD-HSEQ/2024

“Procurement of Fire Hydrant With Monitors for Kunnar / KPD-TAY PLANT”

Sr. #	Description	Unit	Qty.
1.	Fire Water Hydrant 6” Combine with Monitor (without Nozzle)	No.	06 Nos.

TERMS AND CONDITIONS (TECHNICAL):

1. Delivery Period: 04 ~ 06 Weeks after placement of LPO.
2. Wet Pillar type Carbon Steel Construction ASTM A106 Gr. B SCH 40, with 6” hydrant inlet flange with ANSI 150 RF class combine with Monitor
3. 6” Inlet Butterfly Valve C/W lever (Wafer Type) Carbon Steel ASTM A216 WCB (Body)
4. 2X 2.5” Hydrant delivery outlets equipped with Gun metal Gate valve size 2.5”
5. Brass Female instant coupling 2.5” BS 336 F with male cap (PVC material) C/W chain
6. Monitor flow will be 250 gpm at 100 Psi with 360° rotation, Min. -20° to 75° vertical. Lockable in any position
7. Supplier has to submit Third party hydro test certificate at 260 Psi.
8. Bidder should provide standard warranty guaranty of the supplied material as per tender requirement.
9. Finishing epoxy painted with Red RAL 3000 with 125 micron paint coating
10. Supplier has to submit MTC (Material Testing Certificate) alongwith shipment.
11. Supplier to provide material at KUNNAR/KPD-TAY Site on FOR basis.
12. Payment will be made after inspection, acceptance & performance testing of material.
13. In case of any non-conformance observed during inspection, Supplier shall immediately rectify / replace the same. Any delay in rectification will be liable to LDs as per OGDCL standard tender document.
14. Supplier has to submit the Annex-C of GST submission to FBR against same invoice.
15. The master set of tender documents (Local) available on OGDCL website (www.ogdcl.com) is the integral part of this tender.

GENERAL TERMS AND CONDITIONS:

- A. BIDS MUST BE SUBMITTED UNDER **SINGLE STAGE TWO ENVELOPES BIDDING SYSTEM** i.e. TECHNICAL & FINANCIAL BID SEPARATELY ON DUE DATE.
- B. FINANCIAL BIDS OF ONLY TECHNICALLY RESPONSIVE BIDDERS WILL BE OPENED PUBLICLY.
- C. AFTER TENDER OPENING "TECHNICAL BIDS" WILL BE REVIEWED. THE BIDS WILL BE BROUGHT TECHNICALLY AT PAR BY SEEKING CLARIFICATIONS. THE BIDDERS WILL **NOT** BE ASKED FOR ANY PRICE CHANGE IN THEIR FINANCIAL BIDS DUE TO CERTAIN CLARIFICATIONS AND SUBSEQUENT CHANGE IN THEIR TECHNICAL PROPOSALS. THE BIDDERS WILL **NOT** BE ALLOWED TO SUBMIT SUPPLEMENTARY PRICE PROPOSALS IN A SEPARATE SEALED ENVELOPE TO MAKE IT A PART OF THE ALREADY SUBMITTED UNOPENED FINANCIAL BIDS AND TO ADJUST THEIR QUOTED PRICE SUBSEQUENTLY AFFECTED DUE TO CHANGE IN TECHNICAL PROPOSALS.
- D. SEALED FINANCIAL BIDS OF TECHNICALLY NON-RESPONSIVE BIDDERS WILL BE RETURNED UN-OPENED.
- E. OGDCL RESERVES THE RIGHT TO REJECT ANY OR ALL THE BIDS WITHOUT ASSIGNING ANY REASON.
- F. PRICES MUST BE QUOTED IN PKR INCLUSIVE OF ALL TAXES AND DUTIES, INDICATING UNIT PRICE AND TOTAL BID PRICES. GST MUST BE QUOTED SEPARATELY ALONG WITH COPY OF GST CERTIFICATE.
- G. QUOTED PRICES SHALL BE VALID FOR **90 DAYS** FROM THE OPENING DATE OF THE TECHNICAL BID.
- H. BIDDERS TO SUBMIT THEIR COMPANY PROFILES, EXPERIENCE OF SIMILAR SUPPLIES IN PAKISTAN ALONG WITH TECHNICAL BIDS.