

FINAL EVALUATION REPORT
As Per Rule 35 of PPRA Rules, 2004

1	Name of Procuring Agency	Oil & Gas Development Company Limited, IBA
2	Method of Procurement:	Press Tendering
3	Title of Procurement:	Procurement of LED Flood lights 300W for Boundary wall of Qadirpur field
4	RFP No.	OGDCL-SCM-LF-PT-PENFD-QPR-231411917-2023
5	PPRA Ref. No. (TSE):	
6	Date & Time of Bid Closing:	07.02.2024 @11:30 HRS
7	Date & Time of Bid Opening:	07.02.2024@12:00 HRS
8	No. of Bids Received:	08
9	Criteria for Bid Evaluation:	Full Consignment/Complete Package

Details of Bid(s) Evaluation:

Name of Bidder	Marks		Total Evaluated Cost w/o GST (PKR)	Rule/Regulation/SBD*/Policy/Basis for Rejection/Acceptance as per Rule 35 of PP Rules, 2004
	Technical (if applicable)	Financial (if applicable)		
Amin Engineering Company, Daharki	Not Applicable		2,430,000.00	Technically Responsive & Financially most advantageous
Smart Power Systems Pvt. Limited, Karachi	Not Applicable		3,429,000.00	Technically Responsive and financially higher
Pak Multi Services (Pvt.) Ltd., Rawalpindi	Not Applicable		1,620,000.00	Technically non-Responsive due to material deviation clause no. 3.1 of RFP (Quoted LED flood lights have following deviations: <ul style="list-style-type: none"> ▪ lighting efficiency of 110 lumens/watt instead of required 150 lumens/watt ▪ operating temperature range is -25 to 40°C instead of required -30 to 60°C ▪ Protection rate is IP65 instead of required IP 66)
Pegasus, Karachi	Not Applicable		1,908,738.00	Technically non-Responsive due to material deviation clause no. 3.1 of RFP (Quoted LED flood lights have following deviations: <ul style="list-style-type: none"> ▪ lighting efficiency of 125 lumens/watt instead of required 150 lumens/watt ▪ operating temperature range is -30 to 50°C instead of required -30 to 60°C)
Tasbeel Engineering & Services, Ghotki	Not Applicable		2,135,700.00	Technically non-Responsive due to material deviation clause no. 3.1 of RFP (Quoted LED flood lights have following deviations: <ul style="list-style-type: none"> ▪ lighting efficiency of 140 lumens/watt instead of required 150 lumens/watt ▪ operating temperature range is -30 to 56°C instead of required -30 to 60°C)
Tri Alpha Enterprises, Multan	Not Applicable		2,778,300.00	Technically non-Responsive due to material deviation clause no. 3.1 of RFP (Operating temperature of quoted LED flood lights is -30 to 50°C instead of required -30 to 60°C)
Global Links International, Islamabad	Not Applicable		4,009,500.00	Technically non-Responsive due to material deviation clause no. 3.1 of RFP (Quoted LED flood lights have lighting efficiency of 130 lumens/watt instead of required 150 lumens/watt)
Protech Solutions Pvt. (Ltd), Islamabad	Not Applicable		31,516,992.00	Technically non-Responsive due to material deviation clause no. 3.1 of RFP (Quoted LED flood lights have following deviations: <ul style="list-style-type: none"> ▪ lighting efficiency of 100 lumens/watt instead of required 150 lumens/watt ▪ Protection rate is IP65 instead of required IP 66)

Most Advantageous Bidder: Amin Engineering Company, Daharki

Note:

- Bidder may submit grievance within seven (07) days of announcement of Final Evaluation Report.
- The grievance if any shall be sent to bgrc@ogdcl.com as per format available on OGDCL website.