



NOTE 1: – All welding to be done with co2 welding machine.
2: – Roof shall be provided 30 mm slop from centre.
3: – Design Code API-650.

NOTE THE BRACING (ANGLE) SHOULD BE TACK WELDED 3" AT 9" PITCH ZIG-ZAG.

DRAWING HISTORY	
ISSUE	PURPOSE
8	
7	
6	
5	

Approved	Rashid Mehmood
Checked	Fasih Akhtar
Design by	Arfan Butt
CAD by	Abid Hussain Shah
Project Engineer	

Scale:	NTS
File Name:	TK-MS500_Heating_coilDWG
Dated:	17-04-2012
Drawing No.	TK-MS-500-Heating-Coils
Sheet No.	1 of 2

Project: **OIL STORAGE TANK (500 BBL) WITH HEATING COILS**

Client: **Oil & Gas Development Corporation Ltd**

Department: **Petroleum Engg. & Facilities Deptt.**

Division: **Production Division**

Size: **A3**