




**NOTES:-**

1. CABLE MARKERS WITH APPROPRIATE TEXT AND COLORS SHALL BE ERECTED AT A 20 METER INTERVAL ALONG THE STRAIGHT TRENCH, AND AT EACH BEND FOR INDICATION OF PRESENCE OF UNDERGROUND CABLES.



- 1- MARKER TO BE SUNK TO GROUND LEVEL ON ROAD WAY CROSSING .
- 2- COLOUR CODE AS FOLLOWS-
  - a- ORANGE 1-11 kV HIGH POWER CABLE
  - b- BLUE 110-1000 V POWER & CONTROL
  - c- GREEN GROUNDING

**CABLE RUN MARKER POST**

ISSUED FOR TENDER

0	09-03-2018	ISSUED FOR TENDER	MAA	JAB	AIB	MAS
A	29-12-2017	ISSUED FOR REVIEW & APPROVAL	MAA	JAB	AIB	AHB
REV.	DATE	DESCRIPTION OF REVISION	DRAWN	DESIGNED	CHECKED	APPR.
<b>ENAR PETROTECH SERVICES (PRIVATE) LIMITED</b> 7-B, Sector 7-A Korangi Industrial Area, Karachi Pakistan TEL: (9221) 5062791 E-mail: info@enar.com.pk URL: www.enar.com.pk			Job No. <b>14-019:</b> Dwg. No. <b>0193-ELA-6800</b> Sheet 8 OF 15			
<b>OIL &amp; GAS DEVELOPMENT COMPANY LIMITED</b> <b>NASHPA COMPRESSION PROJECT (PHASE-II)</b>			COMPUTER CODE: 0193-ELA-6800 SHEET SIZE: A3 SCALE: NTS REPLACES Dwg. No.: -			
TYPICAL DETAIL FOR CABLE RUN MARKER POST			THIS DOCUMENT IS THE PROPERTY OF ENAR & THE CONTENTS MUST BE TREATED AS CONFIDENTIAL.			