




DETAIL - 1




DETAIL - 2




DETAIL - C




PLAN




SECTION A-A



SECTION C - C



VIEW - A



SECTION B - B

ITEM NO.	DESCRIPTION
1	200mm NOMINAL DIA M.S. PIPE THICKNESS 7mm O.D = 219mm
2	150mm NOMINAL DIA M.S. PIPE THICKNESS 4.85mm O.D = 168mm
3	100mm NOMINAL DIA M.S. PIPE THICKNESS 4.78mm O.D = 114mm
4	CHANNEL 160x65, 18.8 Kg./m.
5	6mm THICK M.S. PLATE (WELDED)
6	6mm THICK M.S. PLATE 200x165 Sq.mm
7	EARTHING TERMINAL
8	POWER CABLE 3x2.5 Sq.mm
9	MOUNTING PLATE 4mm THICK STEEL
10	CABLE ENTRY/EXIT HOLE (80x22)
11	WEATHER/WATER OR EXPLOSION PROOF (EExd) FLOOD LIGHT FIXTURE WITH 120W LED TYPE
12	20mm $\phi$ HOLE FOR FIXING OF LIGHT FIXTURE BRACKET
13	20x60mm $\phi$ HOLE FOR FIXING OF LIGHT FIXTURE BRACKET
14	STEEL SADDLE CLAMP
15	PROTECTIVE MILD STEEL PIPE $\phi$ 25mm
16	PROTECTIVE MILD STEEL PIPE $\phi$ 38mm
17	POWER CABLE 4/10 Sq.mm 4 CORE
18	WEATHER/WATER OR EXPLOSION PROOF (EExd) FUSE CONNECTOR JUNCTION BOX
19	50mm DIA POWER CABLE HOLE

NOTES:-

1. ALL DIMENSIONS ARE IN mm UNLESS OTHERWISE SPECIFIED.
2. EVERY ITEM SHALL BE ADEQUATELY TROPICALISED & PROTECTED AGAINST CORROSION.
3. SUPPORT FOR JB INSTALLATION ON THE POLE SHALL BE PROVIDED WITH POLE.
4. CONDUIT MENTIONED IN VIEW A SHALL BE SUPPLIED & INSTALLED BY THE CONTRACTOR.
4. CIVIL WORK REQUIRED FOR THE INSULATION FOR POLE IN THE SCOPE OF THE CONTRACTOR.

ISSUED FOR TENDER

0	09-03-2018	ISSUED FOR TENDER	MAA	JAB	AIB	MAS
A	29-12-2017	ISSUED FOR REVIEW & APPROVAL	MAA	JAB	AIB	AHB
REV.	DATE	DESCRIPTION OF REVISION	DRAWN	DESIGNED	CHECKED	APPR.
ENAR PETROTECH SERVICES (PRIVATE) LIMITED 7-B, Sector 7-A Korangi Industrial Area, Karachi Pakistan TEL: (9221) 5062791 E-mail: info@enar.com.pk URL: www.enar.com.pk			Job No. 14-019:			
OIL & GAS DEVELOPMENT COMPANY LIMITED NASHPA COMPRESSION PROJECT (PHASE-II)			Dwg. No. 0193-ELA-6800			
TYPICAL INSTALLATION DETAILS FOR FLOOD LIGHT POLES			Sheet 4 OF 15			
COMPUTER CODE	0193-ELA-6800					
SHEET SIZE	A3					
SCALE	NTS					
REPLACES DWG. NO.	-					
THIS DOCUMENT IS THE PROPERTY OF ENAR & THE CONTENTS MUST BE TREATED AS CONFIDENTIAL						