



LEGEND	
ITEM NO.	DESCRIPTION
1	ELECTRICAL CABLE
2	C.S. PROTECTIVE PIPES 200mm DIA.
3	CONCRETE FILLING 1:2:4 MIX CONCRETE
4	BAKED BRICKS 300x150x50mm HAVING EMBOSSED PERMANENT MARKING CABLE

- NOTES:-**
1. ALL DIMENSIONS ARE IN mm UNLESS OTHER WISE SPECIFIED.
 2. SEAL THE PIPES ENDS AT BOTH SIDES.
 3. REFER SLEEVE SCHEDULE OF DOCUMENT # XXXX-XX-XXXX FOR BOTTOM OF PIPE (B.O.P) AND SLEEVE LENGTH.
 3. THE MINIMUM DEPTH SHALL BE 800mm. HOW EVER DUE TO DIFFERENCE IN FGL LEVELS ON THE ROAD SIDES THE DEPTH SHALL BE ADJUSTED TO AVOID SLOPE OF SLEEVES AND KEEP THE SLEEVES STRAIGHT

ISSUED FOR TENDER

O	09-03-2018	ISSUED FOR TENDER	MAA	JAB	AIB MAS
A	29-12-2017	ISSUED FOR REVIEW & APPROVAL	MAA	JAB	AIB AHB
REV.	DATE	DESCRIPTION OF REVISION	DRAWN	DESIGNED	CHECKED APPR.
<div><div><div>ENAR</div></div><div>ENAR PETROTECH SERVICES (PRIVATE) LIMITED 7-B, Sector 7-A Korangi Industrial Area, Karachi Pakistan TEL: (9221) 5062791 E-mail: info@enar.com.pk URL: www.enar.com.pk</div></div> <div>OIL & GAS DEVELOPMENT COMPANY LIMITED</div> <div>NASHPA COMPRESSION PROJECT (PHASE-II)</div> <div>TITLE: TYPICAL DETAIL FOR DRAWING FOR ROAD CROSSING</div>			Job No.		
			14-019		
			Dwg. No.		
			0193-ELA-6800		
			Sheet 9 Of 15		
			COMPUTER CODE	0193-ELA-6800	
			SHEET SIZE	A3	
			SCALE	NTS	
			REPLACES DWG. NO.	—	
THIS DOCUMENT IS THE PROPERTY OF ENAR & THE CONTENTS MUST BE TREATED AS CONFIDENTIAL					