

GENERAL NOTES

- ALL DIMENSIONS ARE IN MILLIMETERS UNLESS NOTED OTHERWISE.
- LOCATION SHALL BE VERIFIED WITH THE LATEST LAYOUT SHOWN IN REF. No. NGP-000-SCW-15.01-2004-23 STORM WATER DRAINAGE PLAN.
- FOR GENERAL NOTES FOR REINFORCED CONCRETE WORKS REFER DWG NO. NGP-000-SCW-15.01-0001-00.
- MINIMUM CYLINDER COMPRESSIVE STRENGTH OF CONCRETE AT 28DAYS.
 - STRUCTURAL CONCRETE : $F_c = 21\text{MPa}$
 - LEAN CONCRETE : $F_c = 14\text{MPa}$
- YIELD STRENGTH OF REINFORCEMENT BAR
 - $F_y = 420\text{MPa}$, ASTM A615, DENOTED WITH "T"
- FOR GALVANIZED STEEL GRATING SHALL FOLLOW THE REQUIREMENT OF DWG. NO. NGP-000-SCW-15.01-0017-00.
- THE HEIGHT NEEDS TO BE REFERRED FROM STORM WATER DRAINAGE PLAN.

REFERENCE DOCUMENTS

TITLE	DOC No.
DESIGN BASIS FOR CIVIL AND STEEL STRUCTURES WORKS	NGP-000-SCW-15.05-0001-00
SPECIFICATION FOR EARTH WORK AND SITE PREPARATION	NGP-000-SCW-15.03-2001-00
STANDARD DRAWING OF ROAD SECTIONS	NGP-000-SCW-15.01-2001-23
GENERAL PLOT PLAN	NGP-000-GEN-15.01-0001-00
SIT GRADING AND LEVELING PLAN	NGP-000-SCW-15.01-2005-23
GRADING AND VERTICAL PLAN	NGP-000-SCW-15.01-2006-23
RIPRAP SLOPE PROTECTION LAYOUT	NGP-000-SCW-15.01-2007-23
STORM WATER DRAINAGE PLAN	NGP-000-SCW-15.01-2004-23
STANDARD DRAWING FOR STORM WATER	NGP-000-SCW-15.01-0010-00

REV.	DESCRIPTION	PRPD	CHKD	REVD	APPD	DATE
00	Approved for Construction	XIAO.	YANG.	ZHANG.	QIU.	05/07/2016
C1	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	08/06/2016
C	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	20/05/2016
B	Issued for Review	XIAO.	YANG.	ZHANG.	QIU.	28/04/2016
A	Internal Discipline Check	XIAO.	YANG.	ZHANG.	QIU.	20/04/2016


CLIENT: **OIL&GAS DEVELOPMENT COMPANY LTD.**
OCDCL HOUSE TOWER 6, FIRST FLOOR F1906, BLUE AREA, JINNAH AVENUE ISLAMABAD PAKISTAN
FAX: +92 001 282205, PHONE: +92 001 282205

CONSULTANT: **Zishan Engineers (Pvt.) Ltd.**
An ISO 9001-2008 certified company
47/F Block 6, PECH-85, Kamachi-Pakistan
Tel: (92-91) 3436340-43 & 34310101-54, Fax: (92-91) 34333430 & 34310158
E-Mail: contact@zishanengineers.com Website: www.zishanengineers.com


CONTRACTOR: **HONG KONG HUIHUA GLOBAL TECHNOLOGY LIMITED**
PROJECT NO. NASHPA 1247

PROJECT TITLE: **NASHPA GAS PROCESSING AND LPG RECOVERY PLANT PROC-FC-CB/NASHPA/PROJ-1247/2016**
DRAWING NO. NGP-000-SCW-15.01-2010-23


DRAWING TITLE: **DETAIL DRAWING OF STORM WATER DRAIN DITCH**
REV. 00 SCALE NTS SHEET 1 OF 6




TYPICAL PLAN OF DRAIN DITCH
WIDTH=800mm SCALE 1:20



SECTION A-A
SCALE 1:20



DETAIL 1
NTS



SECTION A-A
REINFORCEMENT DETAIL

GENERAL NOTES

- ALL DIMENSIONS ARE IN MILLIMETERS UNLESS NOTED OTHERWISE.
- LOCATION SHALL BE VERIFIED WITH THE LATEST LAYOUT SHOWN IN REF. No. NGP-000-SCW-15.01-2004-23 STORM WATER DRAINAGE PLAN.
- FOR GENERAL NOTES FOR REINFORCED CONCRETE WORKS REFER DWG NO. NGP-000-SCW-15.01-0001-00.
- MINIMUM CYLINDER COMPRESSIVE STRENGTH OF CONCRETE AT 28DAYS.
 - STRUCTURAL CONCRETE : $F_c = 21\text{MPa}$
 - LEAN CONCRETE : $F_c = 14\text{MPa}$
- YIELD STRENGTH OF REINFORCEMENT BAR
 - $F_y = 420\text{MPa}$, ASTM A615, DENOTED WITH "T"
- FOR GALVANIZED STEEL GRATING SHALL FOLLOW THE REQUIREMENT OF DWG. NO. NGP-000-SCW-15.01-0017-00.
- THE HEIGHT NEEDS TO BE REFERRED FROM STORM WATER DRAINAGE PLAN.

REFERENCE DOCUMENTS

TITLE	DOC No.
DESIGN BASIS FOR CIVIL AND STEEL STRUCTURES WORKS	NGP-000-SCW-15.05-0001-00
SPECIFICATION FOR EARTH WORK AND SITE PREPARATION	NGP-000-SCW-15.03-2001-00
STANDARD DRAWING OF ROAD SECTIONS	NGP-000-SCW-15.01-2001-23
GENERAL PLOT PLAN	NGP-000-GEN-15.01-0001-00
SIT GRADING AND LEVELING PLAN	NGP-000-SCW-15.01-2005-23
GRADING AND VERTICAL PLAN	NGP-000-SCW-15.01-2006-23
RIPRAP SLOPE PROTECTION LAYOUT	NGP-000-SCW-15.01-2007-23
STORM WATER DRAINAGE PLAN	NGP-000-SCW-15.01-2004-23
STANDARD DRAWING FOR STORM WATER	NGP-000-SCW-15.01-0010-00

REV.	DESCRIPTION	PRPD	CHKD	REVD	APPD	DATE
00	Approved for Construction	XIAO.	YANG.	ZHANG.	QIU.	05/07/2016
C1	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	08/06/2016
C	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	20/05/2016
B	Issued for Review	XIAO.	YANG.	ZHANG.	QIU.	28/04/2016
A	Internal Discipline Check	XIAO.	YANG.	ZHANG.	QIU.	20/04/2016


CLIENT: **OIL&GAS DEVELOPMENT COMPANY LTD.**
O&G HOUSE TOWER 1, FIRST FLOOR, BLUE AREA, JINNAH AVENUE ISLAMABAD PAKISTAN
TEL: +92 001 222222, PHONE: +92 001 222222

CONSULTANT: **Zishan Engineers (Pvt.) Ltd.**
An ISO 9001-2008 certified company
47/F, Block B, PECH-85, Kamahi-Pakistan
Tel: (92-91) 3436340-43 & 34370101-54, Fax: (92-91) 34333430 & 34370108
E-Mail: contact@zishanengineers.com Website: www.zishanengineers.com


CONTRACTOR: **HONG KONG HUIHUA GLOBAL TECHNOLOGY LIMITED**
PROJECT NO. NASHPA 1247

PROJECT TITLE: **NASHPA GAS PROCESSING AND LPG RECOVERY PLANT PROC-FC-CB/NASHPA/PROJ-1247/2015**
DRAWING NO. NGP-000-SCW-15.01-2010-23


DRAWING TITLE: **DETAIL DRAWING OF STORM WATER DRAIN DITCH**
REV. 00
SCALE NTS
SHEET 2 OF 6




TYPICAL PLAN OF DRAIN DITCH
WIDTH=1000mm SCALE 1:20



SECTION A
SCALE 1:20



DETAIL 1
NTS



SECTION A
REINFORCEMENT DETAIL

GENERAL NOTES

- ALL DIMENSIONS ARE IN MILLIMETERS UNLESS NOTED OTHERWISE.
- LOCATION SHALL BE VERIFIED WITH THE LATEST LAYOUT SHOWN IN REF. No. NGP-000-SCW-15.01-2004-23 STORM WATER DRAINAGE PLAN.
- FOR GENERAL NOTES FOR REINFORCED CONCRETE WORKS REFER DWG NO. NGP-000-SCW-15.01-0001-00.
- MINIMUM CYLINDER COMPRESSIVE STRENGTH OF CONCRETE AT 28DAYS.
 - STRUCTURAL CONCRETE : $F_c = 21\text{MPa}$
 - LEAN CONCRETE : $F_c = 14\text{MPa}$
- YIELD STRENGTH OF REINFORCEMENT BAR
 - $F_y = 420\text{MPa}$, ASTM A615, DENOTED WITH "T"
- FOR GALVANIZED STEEL GRATING SHALL FOLLOW THE REQUIREMENT OF DWG. NO. NGP-000-SCW-15.01-0017-00.
- THE HEIGHT NEEDS TO BE REFERRED FROM STORM WATER DRAINAGE PLAN.

REFERENCE DOCUMENTS

TITLE	DOC No.
DESIGN BASIS FOR CIVIL AND STEEL STRUCTURES WORKS	NGP-000-SCW-15.05-0001-00
SPECIFICATION FOR EARTH WORK AND SITE PREPARATION	NGP-000-SCW-15.03-2001-00
STANDARD DRAWING OF ROAD SECTIONS	NGP-000-SCW-15.01-2001-23
GENERAL PLOT PLAN	NGP-000-GEN-15.01-0001-00
SIT GRADING AND LEVELING PLAN	NGP-000-SCW-15.01-2005-23
GRADING AND VERTICAL PLAN	NGP-000-SCW-15.01-2006-23
RIPRAP SLOPE PROTECTION LAYOUT	NGP-000-SCW-15.01-2007-23
STORM WATER DRAINAGE PLAN	NGP-000-SCW-15.01-2004-23
STANDARD DRAWING FOR STORM WATER	NGP-000-SCW-15.01-0010-00

REV.	DESCRIPTION	PRPD	CHKD	REVD	APPD	DATE
00	Approved for Construction	XIAO.	YANG.	ZHANG.	QIU.	05/07/2016
C1	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	08/06/2016
C	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	20/05/2016
B	Issued for Review	XIAO.	YANG.	ZHANG.	QIU.	28/04/2016
A	Internal Discipline Check	XIAO.	YANG.	ZHANG.	QIU.	20/04/2016

CLIENT.	OIL&GAS DEVELOPMENT COMPANY LTD. O&G HOUSE TOWER 1A, FIRST FLOOR, BLUE AREA, JINNAH AVENUE ISLAMABAD PAKISTAN TAX: +92 343 3430, PHONE: +92 343 3430
---------	---


CONSULTANT.	Zishan Engineers (Pvt.) Ltd. An ISO 9001-2008 certified company 47/F Block B, PECH-85, Kamachi-Pakistan Tel: (92-91) 3436340-43 & 34310101-54, Fax: (92-91) 3433430 & 34310108 E-Mail: contact@zishanengineers.com Website: www.zishanengineers.com
-------------	--

CONTRACTOR.	HONG KONG HUIHUA GLOBAL TECHNOLOGY LIMITED	PROJECT NO. NASHPA 1247
-------------	---	----------------------------


PROJECT TITLE: NASHPA GAS PROCESSING AND LPG RECOVERY PLANT PROC-FC-CB/NASHPA/PROJ-1247/2016	DRAWING NO. NGP-000-SCW-15.01-2010-23
--	--

DRAWING TITLE: DETAIL DRAWING OF STORM WATER DRAIN DITCH	REV. SCALE SHEET
	00 NTS 3 OF 6

TYPICAL PLAN OF DRAIN DITCH FOR ROAD CROSS
WIDTH=500mm
SCALE 1:20



SECTION
SCALE 1:20



GENERAL NOTES

- ALL DIMENSIONS ARE IN MILLIMETERS AND ALL ELEVATIONS ARE IN METERS UNLESS NOTED OTHERWISE.
- LOCATION SHALL BE VERIFIED WITH THE LATEST LAYOUT SHOWN IN REF. No. NGP-000-SCW-15.01-2004-23 STORM WATER DRAINAGE PLAN.
- FOR GENERAL NOTES FOR REINFORCED CONCRETE WORKS REFER DWG NO. NGP-000-SCW-15.01-0001-00.
- MINIMUM CYLINDER COMPRESSIVE STRENGTH OF CONCRETE AT 28DAYS.
 - STRUCTURAL CONCRETE : $F_c = 28\text{MPa}$
 - LEAN CONCRETE : $F_c = 14\text{MPa}$
- YIELD STRENGTH OF REINFORCEMENT BAR
 - $F_y = 420\text{MPa}$, ASTM A615, DENOTED WITH "T"
- FOR GALVANIZED STEEL GRATING SHALL FOLLOW THE REQUIREMENT OF DWG. NO. NGP-000-SCW-15.01-0017-00.
- THE HEIGHT NEEDS TO BE REFERRED FROM STORM WATER DRAINAGE PLAN.

REFERENCE DOCUMENTS

TITLE	DOC No.
DESIGN BASIS FOR CIVIL AND STEEL STRUCTURES WORKS	NGP-000-SCW-15.05-0001-00
SPECIFICATION FOR EARTH WORK AND SITE PREPARATION	NGP-000-SCW-15.03-2001-00
STANDARD DRAWING OF ROAD SECTIONS	NGP-000-SCW-15.01-2001-23
GENERAL PLOT PLAN	NGP-000-GEN-15.01-0001-00
SIT GRADING AND LEVELING PLAN	NGP-000-SCW-15.01-2005-23
GRADING AND VERTICAL PLAN	NGP-000-SCW-15.01-2006-23
RIPRAP SLOPE PROTECTION LAYOUT	NGP-000-SCW-15.01-2007-23
STORM WATER DRAINAGE PLAN	NGP-000-SCW-15.01-2004-23
STANDARD DRAWING FOR STORM WATER	NGP-000-SCW-15.01-0010-00

		Xiao Jiankun	Yang Guohui	Zhang Zhi Xing	Qiu Rui Qi	
00	Approved for Construction	XIAO.	YANG.	ZHANG.	QIU.	05/07/2016
C1	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	08/06/2016
C	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	20/05/2016
B	Issued for Review	XIAO.	YANG.	ZHANG.	QIU.	28/04/2016
A	Internal Discipline Check	XIAO.	YANG.	ZHANG.	QIU.	20/04/2016
REV.	DESCRIPTION	PRPD	CHKD	REVD	APPD	DATE

CLIENT: **OIL&GAS DEVELOPMENT COMPANY LTD.**
O&G POLYMER TOWER, FIRST FLOOR, BLUE AREA, JINNAH AVENUE ISLAMABAD PAKISTAN
TEL: +92 011 222222, PHONE: +92 011 222222

CONSULTANT: **Zishan Engineers (Pvt.) Ltd.**
An ISO 9001-2008 certified company
47/F Block B, PECHS, Kamahi-Pakistan
Tel: (92-91) 3436340-40 & 34370101-54, Fax: (92-91) 34333430 & 34370108
E-Mail: contact@zishanengineers.com Website: www.zishanengineers.com

CONTRACTOR: **HONG KONG HUIHUA GLOBAL TECHNOLOGY LIMITED**
PROJECT NO. NASHPA 1247

PROJECT TITLE: **NASHPA GAS PROCESSING AND LPG RECOVERY PLANT PROC-FC-CB/NASHPA/PROJ-1247/2015**
DRAWING NO. NGP-000-SCW-15.01-2010-23

DRAWING TITLE: **DETAIL DRAWING OF STORM WATER DRAIN DITCH**
REV. 00
SCALE NTS
SHEET 4 OF 6

TYPICAL PLAN OF DRAIN DITCH FOR ROAD CROSS
WIDTH=800mm
SCALE 1:20

SECTION A
SCALE 1:20

GENERAL NOTES

- ALL DIMENSIONS ARE IN MILLIMETERS AND ALL ELEVATIONS ARE IN METERS UNLESS NOTED OTHERWISE.
- LOCATION SHALL BE VERIFIED WITH THE LATEST LAYOUT SHOWN IN REF. No. NGP-000-SCW-15.01-2004-23 STORM WATER DRAINAGE PLAN.
- FOR GENERAL NOTES FOR REINFORCED CONCRETE WORKS REFER DWG NO. NGP-000-SCW-15.01-0001-00.
- MINIMUM CYLINDER COMPRESSIVE STRENGTH OF CONCRETE AT 28DAYS.
 - STRUCTURAL CONCRETE : $F_c = 28\text{MPa}$
 - LEAN CONCRETE : $F_c = 14\text{MPa}$
- YIELD STRENGTH OF REINFORCEMENT BAR
 - $F_y = 420\text{MPa}$, ASTM A615, DENOTED WITH "T"
- FOR GALVANIZED STEEL GRATING SHALL FOLLOW THE REQUIREMENT OF DWG. NO. NGP-000-SCW-15.01-0017-00.
- THE HEIGHT NEEDS TO BE REFERRED FROM STORM WATER DRAINAGE PLAN.

REFERENCE DOCUMENTS

TITLE	DOC No.
DESIGN BASIS FOR CIVIL AND STEEL STRUCTURES WORKS	NGP-000-SCW-15.05-0001-00
SPECIFICATION FOR EARTH WORK AND SITE PREPARATION	NGP-000-SCW-15.03-2001-00
STANDARD DRAWING OF ROAD SECTIONS	NGP-000-SCW-15.01-2001-23
GENERAL PLOT PLAN	NGP-000-GEN-15.01-0001-00
SIT GRADING AND LEVELING PLAN	NGP-000-SCW-15.01-2005-23
GRADING AND VERTICAL PLAN	NGP-000-SCW-15.01-2006-23
RIPRAP SLOPE PROTECTION LAYOUT	NGP-000-SCW-15.01-2007-23
STORM WATER DRAINAGE PLAN	NGP-000-SCW-15.01-2004-23
STANDARD DRAWING FOR STORM WATER	NGP-000-SCW-15.01-0010-00

		Xiao Jiankun	Yang Guohui	Zhang Zhi Xing	Qiu Rui Qi	
00	Approved for Construction	XIAO.	YANG.	ZHANG.	QIU.	05/07/2016
C1	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	08/06/2016
C	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	20/05/2016
B	Issued for Review	XIAO.	YANG.	ZHANG.	QIU.	28/04/2016
A	Internal Discipline Check	XIAO.	YANG.	ZHANG.	QIU.	20/04/2016
REV.	DESCRIPTION	PRPD	CHKD	REVD	APPD	DATE

CLIENT: **OIL&GAS DEVELOPMENT COMPANY LTD.**
O&G HOUSE TOWER 1, FIRST FLOOR, BLUE AREA, JINNAH AVENUE ISLAMABAD PAKISTAN
PAC: +92 343 222222, PHONE: +92 343 222222

CONSULTANT: **Zishan Engineers (Pvt.) Ltd.**
An ISO 9001-2008 certified company
47/F Block B, PECHS, Kamahi-Pakistan
Tel: (92-91) 3436340-43 & 34370101-54, Fax: (92-91) 34333430 & 34370108
E-Mail: contact@zishanengineers.com Website: www.zishanengineers.com

CONTRACTOR: **HONG KONG HUIHUA GLOBAL TECHNOLOGY LIMITED**

PROJECT NO.
NASHPA 1247








PROJECT TITLE: **NASHPA GAS PROCESSING AND LPG RECOVERY PLANT PROC-FC-CB/NASHPA/PROJ-1247/2015**

DRAWING NO.
NGP-000-SCW-15.01-2010-23

DRAWING TITLE: **DETAIL DRAWING OF STORM WATER DRAIN DITCH**

REV. SCALE SHEET
00 NTS 5 OF 6

10 Drawing Size: ISO A2 (V)



SECTION A
REINFORCEMENT DETAIL

GENERAL NOTES

1. ALL DIMENSIONS ARE IN MILLIMETERS AND ALL ELEVATIONS ARE IN METERS UNLESS NOTED OTHERWISE.
2. LOCATION SHALL BE VERIFIED WITH THE LATEST LAYOUT SHOWN IN REF. No. NGP-000-SCW-15.01-2004-23 STORM WATER DRAINAGE PLAN.
3. FOR GENERAL NOTES FOR REINFORCED CONCRETE WORKS REFER DWG NO. NGP-000-SCW-15.01-0001-00.
4. MINIMUM CYLINDER COMPRESSIVE STRENGTH OF CONCRETE AT 28DAYS.
 - STRUCTURAL CONCRETE : $F_c = 28\text{MPa}$
 - LEAN CONCRETE : $F_c = 14\text{MPa}$
5. YIELD STRENGTH OF REINFORCEMENT BAR
 - $F_y = 420\text{MPa}$, ASTM A615, DENOTED WITH "T"
6. FOR GALVANIZED STEEL GRATING SHALL FOLLOW THE REQUIREMENT OF DWG. NO. NGP-000-SCW-15.01-0017-00.
7. THE HEIGHT NEEDS TO BE REFERRED FROM STORM WATER DRAINAGE PLAN.

REFERENCE DOCUMENTS

TITLE	DOC No.
DESIGN BASIS FOR CIVIL AND STEEL STRUCTURES WORKS	NGP-000-SCW-15.05-0001-00
SPECIFICATION FOR EARTH WORK AND SITE PREPARATION	NGP-000-SCW-15.03-2001-00
STANDARD DRAWING OF ROAD SECTIONS	NGP-000-SCW-15.01-2001-23
GENERAL PLOT PLAN	NGP-000-GEN-15.01-0001-00
SIT GRADING AND LEVELING PLAN	NGP-000-SCW-15.01-2005-23
GRADING AND VERTICAL PLAN	NGP-000-SCW-15.01-2006-23
RIPRAP SLOPE PROTECTION LAYOUT	NGP-000-SCW-15.01-2007-23
STORM WATER DRAINAGE PLAN	NGP-000-SCW-15.01-2004-23
STANDARD DRAWING FOR STORM WATER	NGP-000-SCW-15.01-0010-00

REV.	DESCRIPTION	PRPD	CHKD	REVD	APPD	DATE
00	Approved for Construction	XIAO.	YANG.	ZHANG.	QIU.	05/07/2016
C1	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	08/06/2016
B	Issued for Approval	XIAO.	YANG.	ZHANG.	QIU.	20/05/2016
B	Issued for Review	XIAO.	YANG.	ZHANG.	QIU.	28/04/2016
A	Internal Discipline Check	XIAO.	YANG.	ZHANG.	QIU.	20/04/2016

CLIENT: **OIL&GAS DEVELOPMENT COMPANY LTD.**
O&G HOUSE TOWER 1, FIRST FLOOR, BLUE AREA, JINNAH AVENUE ISLAMABAD PAKISTAN
TEL: +92 311 222222, PHONE: +92 311 222222

CONSULTANT: **Zishan Engineers (Pvt.) Ltd.**
An ISO 9001-2008 certified company
47/F Block B, PECHS, Kamahi-Pakistan
Tel: (92-91) 3436343-48 & 34310101-54, Fax: (92-91) 34333430 & 34310108
E-Mail: contact@zishanengineers.com Website: www.zishanengineers.com

CONTRACTOR: **HONG KONG HUIHUA GLOBAL TECHNOLOGY LIMITED**
PROJECT NO. NASHPA 1247

PROJECT TITLE: **NASHPA GAS PROCESSING AND LPG RECOVERY PLANT PROC-FC-CB/NASHPA/PROJ-1247/2016**
DRAWING NO. NGP-000-SCW-15.01-2010-23

DRAWING TITLE: **DETAIL DRAWING OF STORM WATER DRAIN DITCH**
REV. 00
SCALE NTS
SHEET 6 OF 6